



Certificate of Compliance

Certificate Number: LR 22665-1

Revision: LR 22665-6

Date Issued: September 6, 1994

Issued To: CUSTOM COMPONENTS SWITCHES INC
21111 Plummer St
Chatsworth, CA 91311
USA

The products listed below are eligible to bear the CSA Mark.

Issued By: Neil Forsyth, C.E.T.
Edmonton AB, CANADA

Signature

CLASS

3231 02 - SWITCHES - PRESSURE TYPE

PRODUCTS

"Dual-Snap" pressure operated switches. Series 604

PART A - Model 604xJxx rated 15 Amp, 125/250/480 V ac, 0.5 Amp, 250 Vdc.

APPLICABLE REQUIREMENTS

- | | | |
|-------------------------------|---|-----------------------------------------------------------------------------|
| CSA Standard C22.2 No. 0-M91 | - | Definitions and General Requirements |
| CSA Standard C22.2 No. 14-M91 | - | Industrial Control Equipment for Use in Ordinary (Non-Hazardous) Locations. |
| Guide | - | 380-W-1.16 |