

EU DECLARATION OF CONFORMITY

17

We,

Dwyer Instruments, Inc.
102 Indiana Highway 212
Michigan City, IN 46360 USA
+1-219-879-8868

declare under our sole responsibility our Series DPGA Digital Pressure Gauge with 1% Accuracy and Series DPGW Digital Pressure Gauge with 1% Accuracy to which this declaration relates are in conformity with the following EU Directives and harmonized Standards:

Directive 2011/65/EU Restriction of Certain Hazardous Substances in Electrical and Electronic Equipment + Directive (EU) 2015/863 Amendment to Annex II (RoHS)

Directive 2014/30/EU Electromagnetic Compatibility (EMC)

EN 61326-1:2013 Electrical Equipment for Measurement, Control and Laboratory Use - EMC Requirements - Part 1: General Requirements

EN 61000-4-2:2009 Electromagnetic Compatibility (EMC) - Part 4-2: Testing and Measurement Techniques - Electrostatic Discharge Immunity Test

EN 61000-4-3:2006+A1:2008+A2:2010 Electromagnetic Compatibility (EMC) - Part 4-3: Testing and Measurement Techniques - Radiated, Radio-Frequency, Electromagnetic Field Immunity Test

EN 61000-4-8:2010 Electromagnetic Compatibility (EMC) - Part 4-8: Testing and Measurement Techniques - Power Frequency Magnetic Field Immunity Test

EN 55011:2009+A1:2010 Industrial, Scientific and Medical Equipment - Radio-Frequency Disturbance Characteristics - Limits and Methods of Measurement

The authorized representative located within the Community is:

Dwyer Instruments Ltd.
Unit 16, The Wye Estate, London Road
High Wycombe, Bucks HP11 1LH-U.K.
+44 (0) 1494 461707

On behalf of Dwyer Instruments, Inc.,



Doug McCall
Senior Regulatory Engineer
October 14, 2019
Michigan City, Indiana, USA