



14

EC - DECLARATION OF CONFORMITY

We,

Dwyer Instruments, Inc.
P.O. Box 373
Michigan City, IN 46361, USA
(219) 879-8868

declare under our sole responsibility that our Series RHP-E/N, Wall Mount Humidity/Temperature/Dew Point Transmitter, to which this declaration relates, are in conformity with the following EC Directives and harmonized standards:

Directive 2004/108/EC (EMC)

EN 61326-1 (2012) Electrical Equipment for Measurement, Control, and Laboratory Use- EMC Requirements -Part I: General Requirements

EN 61000-6-1 (2007) Electromagnetic compatibility (EMC) - Part 6-1: Generic standards - Immunity for Residential, Commercial and Light-Industrial Environments

EN 61000-6-3 (2007) Electromagnetic compatibility (EMC) - Part 6-3: Generic Standards - Emission Standard for Residential, Commercial and Light-Industrial Environments

IEC 61000-4-2 (2008) Electromagnetic Compatibility (EMC) - Part 4-2: Testing and Measurement Techniques- Electrostatic Discharge Immunity Test

IEC 61000-4-3 (2006 + A1:07, + A2:10) Electromagnetic Compatibility (EMC) - Part 4-3 Testing and Measurement Techniques -Radiated Radio-Frequency, Electromagnetic Field Immunity Test

EN 61000-4-4 (2004 + A1:10) Electromagnetic Compatibility (EMC) Part 4-4 Testing and Measurement Techniques – Electrical Fast Transient/Burst Immunity Test

EN 61000-4-6 (2008) Electromagnetic Compatibility (EMC) Part 4-6 Testing and Measurement Techniques – Immunity to Conducted Disturbances, Induced by Radio-Frequency Fields

EN 55011 (2009 + A1:10) Industrial, Scientific and Medical (ISM) Radio-Frequency Equipment – Electromagnetic Disturbance Characteristics–Limits and Methods of Measurement

The authorized representative located within the Community is:

Dwyer Instruments Ltd
Unit 16, The Wye Estate, London Road
High Wycombe, Bucks HP11 1LH-U.K.
(+44) (0) 1494 461707

On behalf of Dwyer Instruments, Inc.

Senior Regulatory Engineer

Michigan City, Indiana, USA
2/19/14